

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-0067:166 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Siemens Building Technologies Inc., *Fire Safety Div., 8 Fernwood Rd, Florham Park NJ 07932
Contact: Peter Pawchak (973) 593-2662 Fax (973) 593-6652

DESIGN: Strobe speakers, Models SS25, SS70, SSET70, SSET80 and SSET90 with suffixes -15, -15/75, -30 or -75.

Synchronized strobe speakers, Models SS25S-15, -15/75; SS70S-15, -15/75; SSET70S-15/75; SSET80S-15/75 and SSET90S-15. Synchronized strobe speakers must be used with Model SCM-24 sync control module.

Units may follow by suffixes to designate orientation, lettering and color. Numerical suffixes designate minimum candela. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 20-31 VDC/FWR, 60 flashes/minute

INSTALLATION: In accordance with listee's printed instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or Cerberus Pyrotronics, model number, electrical/candela rating and UL label.

APPROVAL: Listed as audible/visual signaling devices for the hearing impaired when used in conjunction with separately listed compatible fire alarm control units. Synchronized strobe speakers and Models with numerical suffix -15/75 are intended for wall mount only. All other models are suitable for ceiling/wall mount installation. For indoor use only.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

XLF: 7125-0785:125

*Rev. 10-26-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

OCTOBER 26, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager